

A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

**Analysis Report For:**

Adirondack Central School District  
110 Ford Street  
Boonville, NY 13309

Report Number: 232889

Page 1/10

---

Sample Number: 10262318C      Sample ID: Boonville Elementary  
Collection Date: 10/25/23      Boonville, NY  
Collection Time: 7:52 am  
Date Received: 10/26/23      Location: BE-116-01  
Time Received: 10:52 am  
Matrix: Potable Water      Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0013	mg/L	11/03/23	11/03/23
Analyzed by ELAP ID#: 10478				

---

Sample Number: 10262319C      Sample ID: Boonville Elementary  
Collection Date: 10/25/23      Boonville, NY  
Collection Time: 7:49 am  
Date Received: 10/26/23      Location: BE-114-01  
Time Received: 10:52 am  
Matrix: Potable Water      Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0010	mg/L	11/03/23	11/03/23
Analyzed by ELAP ID#: 10478				

---

Sample Number: 10262320C      Sample ID: Boonville Elementary  
Collection Date: 10/25/23      Boonville, NY  
Collection Time: 8:03 am  
Date Received: 10/26/23      Location: BE-124-01  
Time Received: 10:52 am  
Matrix: Potable Water      Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0010	mg/L	11/03/23	11/03/23
Analyzed by ELAP ID#: 10478				

---

A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

**Analysis Report For:**

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

Report Number: 232889

Page 2/10

Sample Number: 10262321C  
Collection Date: 10/23/23  
Collection Time: 8:09 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-126-01  
Sample Collector: C. Teachout  
Adirondack CSD

**Method & Parameter**

**Result & Qualifiers**

**Units**

**Analysis Date/Time**

EPA 200.8

Lead, Total (Pb)

<0.001

mg/L

Prep Date

11/03/23

Analysis Date

11/03/23

Analyzed by ELAP ID#: 10478

Sample Number: 10262322C  
Collection Date: 10/25/23  
Collection Time: 7:43 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-110-01  
Sample Collector: C. Teachout  
Adirondack CSD

**Method & Parameter**

**Result & Qualifiers**

**Units**

**Analysis Date/Time**

EPA 200.8

Lead, Total (Pb)

0.0037

mg/L

Prep Date

11/03/23

Analysis Date

11/03/23

Analyzed by ELAP ID#: 10478

Sample Number: 10262323C  
Collection Date: 10/25/23  
Collection Time: 8:22 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-151-01  
Sample Collector: C. Teachout  
Adirondack CSD

**Method & Parameter**

**Result & Qualifiers**

**Units**

**Analysis Date/Time**

EPA 200.8

Lead, Total (Pb)

<0.001

mg/L

Prep Date

11/03/23

Analysis Date

11/03/23

Analyzed by ELAP ID#: 10478

A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

**Analysis Report For:**

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

Report Number: 232889

Page 3/10

Sample Number: 10262324C  
Collection Date: 10/25/23  
Collection Time: 8:26 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY

Location: BE-139-01

Sample Collector: C. Teachout  
Adirondack CSD

**Method & Parameter**

**Result & Qualifiers**

**Units**

**Analysis Date/Time**

EPA 200.8

Lead, Total (Pb)

<0.001

mg/L

Prep Date  
11/03/23

Analysis Date  
11/03/23

Analyzed by ELAP ID#: 10478

Sample Number: 10262325C  
Collection Date: 10/25/23  
Collection Time: 8:32 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY

Location: BE-140-01

Sample Collector: C. Teachout  
Adirondack CSD

**Method & Parameter**

**Result & Qualifiers**

**Units**

**Analysis Date/Time**

EPA 200.8

Lead, Total (Pb)

<0.001

mg/L

Prep Date  
11/03/23

Analysis Date  
11/03/23

Analyzed by ELAP ID#: 10478

Sample Number: 10262326C  
Collection Date: 10/25/23  
Collection Time: 8:31 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY

Location: BE-140-02

Sample Collector: C. Teachout  
Adirondack CSD

**Method & Parameter**

**Result & Qualifiers**

**Units**

**Analysis Date/Time**

EPA 200.8

Lead, Total (Pb)

<0.001

mg/L

Prep Date  
11/03/23

Analysis Date  
11/03/23

Analyzed by ELAP ID#: 10478



A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

**Analysis Report For:**

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

**Report Number:** 232889

**Page** 4/10

**Sample Number:** 10262327C  
**Collection Date:** 10/25/23  
**Collection Time:** 8:47 am  
**Date Received:** 10/26/23  
**Time Received:** 10:52 am  
**Matrix:** Potable Water

**Sample ID:** Boonville Elementary  
Boonville, NY  
  
**Location:** BE-302-01  
  
**Sample Collector:** C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
			<u>Prep Date</u>	<u>Analysis Date</u>
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	0.0011	mg/L	11/03/23	11/03/23

**Sample Number:** 10262328C  
**Collection Date:** 10/25/23  
**Collection Time:** 8:51 am  
**Date Received:** 10/26/23  
**Time Received:** 10:52 am  
**Matrix:** Potable Water

**Sample ID:** Boonville Elementary  
Boonville, NY  
  
**Location:** BE-305-01  
  
**Sample Collector:** C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
			<u>Prep Date</u>	<u>Analysis Date</u>
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	<0.001	mg/L	11/03/23	11/03/23

**Sample Number:** 10262329C  
**Collection Date:** 10/25/23  
**Collection Time:** 8:45 am  
**Date Received:** 10/26/23  
**Time Received:** 10:52 am  
**Matrix:** Potable Water

**Sample ID:** Boonville Elementary  
Boonville, NY  
  
**Location:** BE-312-01  
  
**Sample Collector:** C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
			<u>Prep Date</u>	<u>Analysis Date</u>
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	<0.001	mg/L	11/03/23	11/03/23

A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

Report Number: 232889

Page 5/10

Sample Number: 10262330C  
Collection Date: 10/25/23  
Collection Time: 7:45 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-101-01  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262331C  
Collection Date: 10/25/23  
Collection Time: 9:05 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-216-01  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262332C  
Collection Date: 10/25/23  
Collection Time: 2:25 pm  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-116A-01  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

**Analysis Report For:**

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

Report Number: 232889

Page 6/10

Sample Number: 10262333C  
Collection Date: 10/25/23  
Collection Time: 1:54 pm  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-118-01  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	0.0015	mg/L	<u>Prep Date</u> 11/08/23	<u>Analysis Date</u> 11/08/23

Sample Number: 10262334C  
Collection Date: 10/25/23  
Collection Time: 1:57 pm  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-146-01  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	0.0081	mg/L	<u>Prep Date</u> 11/08/23	<u>Analysis Date</u> 11/08/23

Sample Number: 10262335C  
Collection Date: 10/25/23  
Collection Time: 2:00 pm  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-202-01  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	<0.001	mg/L	<u>Prep Date</u> 11/08/23	<u>Analysis Date</u> 11/08/23



A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

Report Number: 232889

Page 7/10

Sample Number: 10262336C  
Collection Date: 10/25/23  
Collection Time: 8:30 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY

Location: BE-140-03

Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	11/08/23	11/08/23
Analyzed by ELAP ID#: 10478				

Sample Number: 10262337C  
Collection Date: 10/25/23  
Collection Time: 8:35 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY

Location: BE-137-01

Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	11/08/23	11/08/23
Analyzed by ELAP ID#: 10478				

Sample Number: 10262338C  
Collection Date: 10/25/23  
Collection Time: 8:15 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY

Location: BE-105-01

Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0017	mg/L	11/08/23	11/08/23
Analyzed by ELAP ID#: 10478				

A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

**Analysis Report For:**

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

Report Number: 232889

Page 8/10

Sample Number: 10262339C  
Collection Date: 10/25/23  
Collection Time: 8:15 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-105-02  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0015	mg/L	11/08/23	11/08/23
Analyzed by ELAP ID#: 10478				

Sample Number: 10262340C  
Collection Date: 10/25/23  
Collection Time: 8:16 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-107-01  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0015	mg/L	11/08/23	11/08/23
Analyzed by ELAP ID#: 10478				

Sample Number: 10262341C  
Collection Date: 10/25/23  
Collection Time: 8:16 am  
Date Received: 10/26/23  
Time Received: 10:52 am  
Matrix: Potable Water

Sample ID: Boonville Elementary  
Boonville, NY  
Location: BE-107-02  
Sample Collector: C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0013	mg/L	11/08/23	11/08/23
Analyzed by ELAP ID#: 10478				



A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

**Analysis Report For:**

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

Report Number: 232889

Page 9/10

---

**Sample Number:** 10262342C      **Sample ID:** Boonville Elementary  
**Collection Date:** 10/25/23      Boonville, NY  
**Collection Time:** 9:08 am  
**Date Received:** 10/26/23      **Location:** BE-224-03  
**Time Received:** 10:52 am  
**Matrix:** Potable Water      **Sample Collector:** C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	0.0035	mg/L	11/08/23	11/08/23
<i>Analyzed by ELAP ID#: 10478</i>				

---

**Sample Number:** 10262343C      **Sample ID:** Boonville Elementary  
**Collection Date:** 10/25/23      Boonville, NY  
**Collection Time:** 9:06 am  
**Date Received:** 10/26/23      **Location:** BE-221-01  
**Time Received:** 10:52 am  
**Matrix:** Potable Water      **Sample Collector:** C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	11/08/23	11/08/23
<i>Analyzed by ELAP ID#: 10478</i>				

---

**Sample Number:** 10262344C      **Sample ID:** Boonville Elementary  
**Collection Date:** 10/25/23      Boonville, NY  
**Collection Time:** 9:01 am  
**Date Received:** 10/26/23      **Location:** BE-211A-01  
**Time Received:** 10:52 am  
**Matrix:** Potable Water      **Sample Collector:** C. Teachout  
Adirondack CSD

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	11/08/23	11/08/23
<i>Analyzed by ELAP ID#: 10478</i>				

---

A & P Water Testing  
P.O. Box 925  
Morrisville, NY 13408  
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

**Analysis Report For:**

Adirondack Central School District  
1157 Fish Creek Road  
West Leyden, NY 13489

**Report Number:** 232889

**Page** 10/10

---

<b>Sample Number:</b> 10262345C	<b>Sample ID:</b> Boonville Elementary
<b>Collection Date:</b> 10/25/23	Boonville, NY
<b>Collection Time:</b> 8:55 am	
<b>Date Received:</b> 10/26/23	<b>Location:</b> BE-210-03
<b>Time Received:</b> 10:52 am	
<b>Matrix:</b> Potable Water	<b>Sample Collector:</b> C. Teachout
	Adirondack CSD

---

<u>Method &amp; Parameter</u>	<u>Result &amp; Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	11/08/23	11/08/23
Analyzed by ELAP ID#: 10478				

---

**Additional Information:**

mg/L=milligrams/liter(ppm)  
<=less than

Disclaimer: The laboratory interpretations of the data obtained and results reported by A & P Water Testing are believed by A & P Water Testing to be accurate and reliable for the sample(s) as received and tested. By accepting this report, the client agrees that the full extent of any and all liability for actual and consequential damages of A & P Water Testing for services performed shall be equal to the fee charged to the client for the services as liquidated damages. No part of this report shall be reproduced, except in full, without written approval of the laboratory.

**Laboratory Approval:**



Annette Popino, Director

  
Date Approved

Test results meet all requirements of NELAC, unless noted  
Raised seal at right indicates original report