

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Adirondack Central School District
1157 Fish Creek Road
West Leyden, NY 13489

Report Number: 232888

Page 1/6

Sample Number: 10262303C
Collection Date: 10/25/23
Collection Time: 3:54 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-204-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262304C
Collection Date: 10/25/23
Collection Time: 3:47 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-104-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	0.0010	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262305C
Collection Date: 10/25/23
Collection Time: 3:49 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-104-02

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Adirondack Central School District
1157 Fish Creek Road
West Leyden, NY 13489

Report Number: 232888

Page 2/6

Sample Number: 10262306C
Collection Date: 10/25/23
Collection Time: 3:42 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-107-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262307C
Collection Date: 10/26/23
Collection Time: 10:14 am
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-165-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262308C
Collection Date: 10/25/23
Collection Time: 3:12 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-163-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	0.0019	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Adirondack Central School District
1157 Fish Creek Road
West Leyden, NY 13489

Report Number: 232888

Page 3/6

Sample Number: 10262309C Collection Date: 10/25/23 Collection Time: 3:17 pm Date Received: 10/26/23 Time Received: 10:52 am Matrix: Potable Water	Sample ID: West Leyden Elementary West Leyden, NY Location: WL-133-01 Sample Collector: C. Teachout Adirondack CSD
--	---

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	11/03/23	11/03/23
<i>Analyzed by ELAP ID#: 10478</i>				

Sample Number: 10262310C Collection Date: 10/25/23 Collection Time: 3:28 pm Date Received: 10/26/23 Time Received: 10:52 am Matrix: Potable Water	Sample ID: West Leyden Elementary West Leyden, NY Location: WL-158-01 Sample Collector: C. Teachout Adirondack CSD
--	---

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	11/03/23	11/03/23
<i>Analyzed by ELAP ID#: 10478</i>				

Sample Number: 10262311C Collection Date: 10/25/23 Collection Time: 3:30 pm Date Received: 10/26/23 Time Received: 10:52 am Matrix: Potable Water	Sample ID: West Leyden Elementary West Leyden, NY Location: WL-155-01 Sample Collector: C. Teachout Adirondack CSD
--	---

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8			<u>Prep Date</u>	<u>Analysis Date</u>
Lead, Total (Pb)	<0.001	mg/L	11/03/23	11/03/23
<i>Analyzed by ELAP ID#: 10478</i>				

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Adirondack Central School District
1157 Fish Creek Road
West Leyden, NY 13489

Report Number: 232888

Page 4/6

Sample Number: 10262312C
Collection Date: 10/25/23
Collection Time: 3:34 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-152-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262313C
Collection Date: 10/25/23
Collection Time: 3:33 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-151-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262314C
Collection Date: 10/25/23
Collection Time: 3:23 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-140-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) Analyzed by ELAP ID#: 10478	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Adirondack Central School District
1157 Fish Creek Road
West Leyden, NY 13489

Report Number: 232888

Page 5/6

Sample Number: 10262315C
Collection Date: 10/25/23
Collection Time: 3:22 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-140-02

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262316C
Collection Date: 10/25/23
Collection Time: 3:24 pm
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-140-03

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

Sample Number: 10262317C
Collection Date: 10/26/23
Collection Time: 10:15 am
Date Received: 10/26/23
Time Received: 10:52 am
Matrix: Potable Water

Sample ID: West Leyden Elementary
West Leyden, NY

Location: WL-138-01

Sample Collector: C. Teachout
Adirondack CSD

<u>Method & Parameter</u>	<u>Result & Qualifiers</u>	<u>Units</u>	<u>Analysis Date/Time</u>	
EPA 200.8 Lead, Total (Pb) <i>Analyzed by ELAP ID#: 10478</i>	<0.001	mg/L	<u>Prep Date</u> 11/03/23	<u>Analysis Date</u> 11/03/23

A & P Water Testing
P.O. Box 925
Morrisville, NY 13408
315-684-3169

NYS DOH ELAP-Accredited Certification ID#: 11405

Analysis Report For:

Adirondack Central School District
1157 Fish Creek Road
West Leyden, NY 13489

Report Number: 232888

Page 6/6

Additional Information:

mg/L=milligrams/liter (ppm)
<=less than

Disclaimer: The laboratory interpretations of the data obtained and results reported by A & P Water Testing are believed by A & P Water Testing to be accurate and reliable for the sample(s) as received and tested. By accepting this report, the client agrees that the full extent of any and all liability for actual and consequential damages of A & P Water Testing for services performed shall be equal to the fee charged to the client for the services as liquidated damages. No part of this report shall be reproduced, except in full, without written approval of the laboratory.

Laboratory Approval:



Annette Popino, Director

11/16/23
Date Approved

Test results meet all requirements of NELAC, unless noted
Raised seal at right indicates original report